

Permit # \_\_\_\_\_

**ELECTRIC ROUGH & TEMP CHECK LIST  
CHECK LIST**

**THIS IS NOT A COMPLETE LIST**



- 
- APPROVED PLANS ON JOB.
  - CHECK THAT THE DWELLING IS WEATHER TIGHT.
  - CHECK THAT NO WATER LINE OR DRAIN IS OVER PANEL.
  - CHECK FOR PANEL CLEARANCES (WORKING SPACE).
  - CHECK PANEL FOR PROPER BONDING/GROUNDING.
  - CHECK WATERLINE & GASLINE FOR BONDING.
  - CHECK FOR DISCONNECT IF REQUIRED.
  - CHECK THAT ANTI-OXI PASTE IS APPLIED IF REQUIRED.
  - CHECK SPACING OF GROUND RODS AND SIZE OF CONDUCTOR.
  - CHECK FOR SMOKE DETECTOR LOCATIONS.
  - CHECK FOR DECK LIGHT LOCATIONS.
  - CHECK DRYER CIRCUIT (30 AMP 10 / 3.WIRE WITH GROUND.)
  - CHECK RANGE CIRCUIT (MUST BE MINIMUM 40 AMP 8/3 WIRE WITH GROUND.)
  - CHECK LOCAITON OF SWITCHES AND LIGHTS (STAIRS / ATTIC / CRAWL).
  - CHECK LOCATION OF STAIRWAY LIGHTS.
  - CHECK FOR TWO CIRCUITS ON KITCHEN COUNTER.
  - CHECK FOR SPACING OF RECEPTACLES/KITCHEN/HOUSE.
  - CHECK FOR RECEPTACLES IN ISLAND IF APPLICABLE.
  - CHECK FOR BOX SIZING.
  - CHECK FOR SUPPORT ON BOTH SIDES OF THREE GANG AND MORE BOXES.

- CHECK LOCATION OF DRILLED HOLES AND INSTALLATION OF KICK PLATES.
- CHECK BOND FOR ALL METAL BOXES/MECHANICAL CONNECTIONS.
- CHECK FAN BOXES AND FLOOR BOXES.
- CHECK THAT EXTERIOR BOXES HAVE BEEN INSTALLED.
- CHECK LOCATION OF PIGTAILS & FAN BOXES.
- CHECK FOR 20 AMP CIRCUIT IN BATHROOM RECEPTICLES.

INSPECTOR \_\_\_\_\_

DATE: \_\_\_\_\_