



### **CHECKLIST FOR "INITIAL" E&S INSPECTIONS**

- Silt fencing shall be installed where necessary to prevent any sediment or unfiltered runoff from leaving the site.
  
- A Construction entrance of at least 70 feet shall be created with filter fabric and #3 stone. A culvert shall be installed in the ditch line.
  
- Inlet and Outlet protections shall be installed where applicable.
  
- There shall be an all weather container easily visible and accessible. One set of approved construction plans and one copy of the site plan shall be on site during all construction activities.
  
- The permit and lot number shall be posted and easily visible.
  
- Sediment that is transported onto a paved or public road surface shall be cleaned thoroughly at the end of each day.